



INSTITUTE FOR TESTING AND CERTIFICATION
763 02 ZLÍN - CZECH REPUBLIC

TESTIMONIAL No. 18 005

confirms that the product

**Plastics linear floor shower drains,
type APZ8, APZ9, APZ10 a APZ18
with metal collar**

manufactured by

**Alca PLAST, s. r. o.
Biskupský dvůr 2095/8
110 00 Praha 1 – Nové Město
Czech Republic
IČ:25655809**

Achieves for specified parameters the values listed in the Annex 1/18 005

The Testimonial is being issued on the basis of the ITC's document as follows:

- Test Report No. 313500349 issued by the accredited laboratory ITC, a.s. Zlín No. 1004, on 2011-08-12 (drains type APZ 8, APZ 9 – Testimonial No. 11 071)
- Test Report No. 313500596/1 issued by the accredited laboratory ITC, a.s. Zlín No. 1004, on 2014-10-20 (drain type APZ 10 – Testimonial No. 14 038)
- Test Report No. 313500847/1 issued by the accredited laboratory ITC, a.s. Zlín No. 1004, on 2018-02-26 (drains type APZ 18)

Conditions of the testimonial use and related information:

1. The testimonial applies only to the above models of the product.
2. The testimonial remains valid, unless there are changes of the manufacturing technology, applied standards or relevant regulations, but at the latest until expiry date.
3. The validity of the testimonial can be verified on www.itozlín.cz

Issued in Zlín, on 2018-02-28
Valid until: 2021-02-28



Ing. Pavel Vaněk
Director of Certification Division

Annex 1/18 005

Technical characteristic	Measuring unit	Value obtained ¹⁾	Value obtained ²⁾	Value obtained ³⁾	Value obtained ⁴⁾	Ascertaining procedures (testing methods)
Appearance	-	- 5)	- 5)	- 5)	- 5)	visually
Odour trap height	mm	28 – 29	28 – 29	29 – 30	28,1–28,3	ČSN EN 1253-1, art. 5.3.1
Odour trap pressure resistance	Pa	640	640	312 – 314	320	ČSN EN 1253-1, art. 5.3.2
Dimensions of openings in the drain grid	mm	6	6	4,02 – 4,05	5	ČSN EN 1253-1, art. 5.1
Odour tightness of gullies incorporating an odour trap	-	No leakage or pressure drop	No leakage or pressure drop	No leakage or pressure drop	No leakage or pressure drop	ČSN EN 1253-1, art. 5.8.1
Flow rate through the drain grid	l/s	0,44	0,46	0,56 – 0,58	0,36–0,37	ČSN EN 1253-1, art. 5.9
Grid loading	-	No cracks or breaks	No cracks or breaks	No cracks or breaks	No cracks or breaks	ČSN EN 1253-1, art. 5.6

- 1) The tests were carried out on the plastic linear floor shower drain, type APZ 8
2) The tests were carried out on the plastic linear floor shower drain, type APZ 9
3) The tests were carried out on the plastic linear floor shower drain, type APZ 10
4) The tests were carried out on the plastic linear floor shower drain, type APZ 18
5) The inner and outer surfaces with no sharp edges and defects affecting the functionality of the outlet or enabling to cause injury.

Issued in Zlín, on 2018-02-28



Pavel Vaněk
Ing. Pavel Vaněk
Director of Certification Division